

VILLAGE OF AMISK

PUBLIC WORKS REPORT

REPORT FROM: Public Works

DATE: June 18, 2019

Brandon has started. Doing a fine job of catching up on the mowing and trimming.

Had Brian's Electric here due to the fire pump's battery exploding. Believes it was due to old age or fluid levels being low.

Fire extinguishers have been checked. All OK.

Wrote my tests. Find out the results on the 1st of July.